

On behalf of
Columbia Metropolitan Airport
HVAC INSPECTION AND PREVENTATIVE MAINTENANCE
SERVICES

ADDENDUM 2

Thursday, July 6, 2023

1. Q: On this bid, are we providing filters and belts/changing them or is that outside the scope?

A: Yes, the contractor provides and installs filters and belts within the contract.

2. Q: Filter list for leased sites

A:

<u>LOCATION</u>	<u>QUANTITY</u>	<u>SIZE</u>
U S Customs	4	20x20x1
	1	20x25x1
Doolittle	3	16x25x1
	2	20x20x1
	1	20x25x1
	3	16x25x2
FedEx	1	20x25x1
	1	18x25x1
Enterprise Car Rental	2	20x20x1
Avis Car Rental	3	20x20x1
National Car Rental	2	20x20x1
	1	16x20x1
Hertz Car Rental	3	20x20x1
Thrifty Car Rental	2	20x20x1
125A Summer Lake	9	20x25x1
125B Summer Lake	9	20x25x1
ACC Buildings		
• 101	4	16x25x2
	8	16x16x2
	16	20x20x1
102	4	20x25x2
	8	20x20x2
	4	20x30x2
103 (New Roof)	4	15x20x2
	2	14x25x2
	6	16x25x2

	2	20x35x2
	4	16x20x2
•	8	20x20x2
	8	20x25x2
	5	16x24x1
	5	18x24x1
103 (Old Roof)	21	16x25x2
	2	20x30x2
	20	16x16x2
	6	20x25x1
	1	18x25x2
National Weather Service	32	16x20x2